



1990 Prospect Ct., Appleton, WI 54914 * 800-801-7590

LIEBAU-LAUN INC
1200 W LIEBAU RD
THIENSVILLE, WI 53092

Home Owner VINTAGE ESTATES
Well ID/Address PUMP HOUSE
Well City
Sample Location PRESSURE TANK
Lab # 360763
Collected By/Date LIEBAU 2/20/2014

Report Date 24-Feb-14

Analyte	Result	Units	LOD	LOQ	Dil	Dig	Date	Run Date	Mthd	Analyst	QC Code
---------	--------	-------	-----	-----	-----	-----	------	----------	------	---------	---------

Inorganic
General

Nitrate Nitrogen	None Detected	mg/l	0.1	0.31	1		2/22/2014	4500F	AAM	1
-------------------------	----------------------	------	-----	------	---	--	-----------	-------	-----	---

NITRATE (as NO₃+NO₂)...A small amount of nitrate may be natural; however, elevated levels are an indication of nutrients entering the groundwater due to human activity. The maximum contaminant level set by the EPA is 10 mg/L (part per million).

LOD Limit of Detection

None Detected = Result was less than the LOD

LOQ Limit of Quantitation

Code

Comment

1

All laboratory QC requirements were met for this sample.

Laboratory Director

Please visit our website at www.cleanwatertesting.com

WI DNR Lab Certification # 445126660

EPA ID# WI 00063

WI Dept of Ag Lab ID # 152673-D3

Page 1 of 1